

CITY OF SPRINGFIELD  
INTER-OFFICE MEMORANDUM

ATTENTION OF \_\_\_\_\_ FILE \_\_\_\_\_

DATE January 23, 1986 \_\_\_\_\_

DEPARTMENT \_\_\_\_\_

On December 10, 1985, Omer Boyce reported that he had gotten a strong gasoline odor in MH #20, in front of Master Wong's on 1328 S. Glenstone, during a routine cleaning of the sanitary sewer. Gene Pabst and I took readings with the explosion meter in this manhole and those around it. The results were:

MH #20	20% L.E.L.
MH #21	0% L.E.L.
MH #22	0% L.E.L.
MH #14	0% L.E.L.
MH #13	0% L.E.L.
MH #12	0% L.E.L.
MH #11	0% L.E.L.
MH #22	0% L.E.L.
MH #27	0% L.E.L.
MH #23	0% L.E.L.
Storm sewer in front of 1538 S. Glenstone	0% L.E.L.

On December 11, 1985 the reading in MH #20 was 0-5% L.E.L. on the explosion meter.

cc: Mr. Bob Schaefer, P.E., Supt. of Sanitary Services  
Mr. Henry Cole, P.E., Sanitary Engineer  
Mr. Chuck Kroeger, MDNR

*Karen Chandler*  
SIGNED Karen Chandler  
Water Pollution Control Inspector II  
Surveillance & Enforcement

1328 S. Glenstone